

Real-Time Monitoring and Assessment of Circuit Breaker Operations for Diagnostics and Control Applications

A.Johnson Antony¹, R.Lingaswaran² and N.Balakumar³

¹Assistant Professor, Department of Electrical and Electronics Engg., Karpagam Inst. of Tech., Coimbatore. Email: johnsonantonyci@gmail.com

²Assistant Professor, Department of Electrical and Electronics Engg., Karpagam Inst. of Tech., Coimbatore. Email: lingeswaran28@gmail.com

³Assistant Professor, Department of Electrical and Electronics Engg., Tamilnadu College of Engg., Coimbatore. Email: eee59_bala@yahoo.co.in

Article Received: 24 February 2017

Article Accepted: 09 March 2017

Article Published: 11 March 2017

ABSTRACT

Circuit breakers (CBs) are very important elements in the power system. They are used to switch other equipment in and out of service. Circuit breakers need to be reliable since their incorrect operation can cause major issues with power system protection and control. Today's practice in monitoring circuit breaker operation and status in real time is reduced to the use of Remote Terminal Units (RTUs) of Supervisory Control and Data Acquisition (SCADA) system to assess CB status. More detailed information about the control circuit performance may be obtained by CB test equipment typically used for maintenance diagnostics. This paper addresses two important issues: a) how improved CB monitoring may be implemented in real-time, and b) what would be the benefits of such an implementation. The results reported in this paper are coming from two research projects, conducted using funding from Center Point Energy and DOE-CERTS aimed at development of software for automated analysis of CB data and the other covering development of the CB data acquisition unit respectively. The paper is devoted to description of a prototype implementation of a real-time CB monitoring system. The system consists of a new CB monitoring data acquisition IED that is located at circuit breaker and captures detailed information about its operation in real-time. The CB files are transferred to the concentrator PC where the application software performs automated analysis and makes an assessment about the operational status of the breaker. The software is based on signal processing and expert system processing. Application example using actual field data is discussed the paper ends with some conclusions, acknowledgments and a list of references.

1. INTRODUCTION

System wide real-time monitoring of circuit breaker operation and statuses currently is implemented using Remote Terminal Units (RTUs) of Supervisory Control and Data Acquisition (SCADA) system. Based on detected voltage levels on circuit breaker contacts, these units are providing information on final statuses of the circuit breakers such as "OPEN" or "CLOSE". The transitions in time of control signals, such as Trip or Close Initiate, X and Y coil currents, Control and Yard DC voltages, Closing Coil and others, used by protection and maintenance engineers for evaluation of CB performance cannot be monitored using RTU and SCADA approach. A solution called Circuit Breaker Monitoring and Analysis (CBMA) developed at Texas A&M University, intends to solve described problems by integrating customized software and hardware solutions into a single, real-time monitoring and analysis system.

The system for real-time monitoring and analysis of circuit breaker operations described in this paper is an extension of widely used portable circuit breaker testing device concept 0. The traditional testing devices are temporally connected to the circuit breaker's control circuit to record analog and digital signals. The operator opens and closes the circuit breaker each time the test is performed and data are recorded. The traditional analysis is done manually by overlaying traces from a "good" case recorded earlier and making a judgment of how different the new case is.

The new solution is based on a new CB monitoring data acquisition IED called Circuit Breaker Monitor (CBM), which would be permanently connected, to the substation

CBs. CBM captures detailed information about each CB operation in real-time, regardless of whether the operation is initiated manually by the operator or automatically by the protection and control equipment and stores them in COMTRADE file format 0, 0. As soon as the relevant CB control circuit signals are recorded and transmitted by wireless link to the concentrator PC, analysis software automatically performs the analysis.

CBMA provides better understanding of the condition and operating performance of each individual breaker by monitoring and analyzing expanded set of analog and digital signals from circuit breaker control circuitry. The advanced signal processing algorithms and knowledge base of the expert system implemented in the analysis software, significantly improve the reliability and consistency of the analysis results. Thanks to the fast and low cost CBM devices, new monitoring and control system described in this paper, enables permanent, real time monitoring of status and performance of circuit breakers for the entire network.

In the first section of the paper, architecture of the whole system and basic processing algorithm are described. Second section explains the structure and basic functions of the hardware part of the system. Focus of the following section is on the organization of analysis software of the CBMA system. Basic building blocks, such as signal processing and expert system are elaborated and brief overview of knowledge base rules is given. At the end, an example of the stuck breaker case is illustrated with waveforms of relevant signals and expert system rules involved in problem detection process.

2. ARCHITECTURE OF CBMA SYSTEM

The CBMA system supports client/server architecture. The client part resides in substation. It consists of the CBM devices attached to the CBs and software running on concentrator PC, both permanently installed in the substation, as shown in Fig.




Fig.1. CBMA system architecture

When breaker operates, recorded files are wirelessly transmitted to the concentrator PC. The client application automatically performs the analysis of recorded signals from the circuit breaker control circuit. For more efficient data manipulation, IEEE file naming convention is used for naming the recordings files. The signal-processing module of the analysis software extracts various parameters from recorded signal samples and expert system evaluates them against empirically obtained values and tolerances selected for specific type of circuit breaker.

The resulting report describes detected abnormalities and possible causes of the problem. If discovered problem presents serious threat to the reliability of future circuit breaker operation, programmable notification is sent to the server located in the central office. The notification is then processed and a warning is sent via email or pager to the maintenance and protection personal. Reporting is provided for both local and geographically dislocated users through implementation of local database and web server supporting information exchange through dynamic HTML pages.

Recorded files and reports can be downloaded to the server via Ethernet network relying on standard, fast and reliable TCP/IP protocol. In the central office or control center, the server part of CBMA consisting of the analysis module, a central database and master web server is running. The central database allows for easy archiving and retrieving of the records and analysis reports from all system substations. Master web application allows remote users to search for the records and/or analysis reports from anywhere on the corporate network (intranet).

2.1 Description of CBMA Hardware

The system hardware in substation consists of circuit breaker monitors located on each breaker in the switchyard and a concentrator PC, used for gathering data, placed in the control room.

2.2 Circuit Breaker monitors IED

The circuit breaker monitor IED (CBM) has three main tasks: Perform data acquisition of signals from the Circuit Breaker control circuit and record sequences of tripping and closing; Convert captured signals into files according to COMTRADE file specifications; Transmit files wirelessly to the concentrator device.




Fig.1. Control circuit of Circuit Breaker

From the circuit breaker control circuit shown in Figure 1. The signals are generated during either tripping or closing of the breaker. Of these 15 signals, 11 are analog and 4 are status signals. The monitored signals are listed in Table 1.

Table 1. Signals of Circuit Breaker Control Circuit monitored by CBMA

Group	Signal name
Digital signals	Trip Initiate
	Close Initiate
	X Coil signal
	Y Coil signal
Contacts	“A” Contact
	“B” Contact
DC Voltages	Control DC Voltage
	Yard DC Voltage
	Light Wire
Coil Currents	Trip Coil (TC) Current 1
	Trip Coil (TC) Current 2
	Closing Coil (CC) Current
Phase Currents	Phase Current A
	Phase Current B
	Phase Current C

The most important signals are Trip Initiate and Close Initiate. These signals, initiated by the relay or the operator, cause generation of some other signals, as a result of the circuit breaker tripping or closing. All of the monitored signals are voltage signals. The signals representing currents are taken from shunts, thus converting them to appropriate voltage signals. In the worst-case scenario time between the fault occurrence and the breaker lockout is about 1 (one) minute. The monitoring device is designed to record and store recorded data for this duration.




Fig.2. Block diagram of CBM

A block diagram of the Circuit Breaker Monitor IED is shown in Fig.2. The system consists of following modules: Signal conditioning boards: The Signal conditioning and isolation module provides appropriate voltage levels for data acquisition. The voltage levels of signals at circuit breaker are either 130VDC or 1 VDC. The signal conditioning module conditions the input signals to be in the [-5, +5] V range as required at the input of the A/D converter module. The module has adjustable gain for all 15 channels. A user determines suitable gain values for the hardware to be used with input signals during set up. The gain can be adjusted by software within a certain range for precise calibration in case of drift over time. The module also provides galvanic isolation of the signals at the input to prevent faults at the input of the module from damaging the rest of the system.

The A/D converter employed has 16 channels and a 16-bit resolution. It takes the input from signal conditioning board and converts it to digital form. The sampling on the 15 channels utilized is synchronous. The sampling rate used is 5760 Hz but can be modified by software depending on the capability of the A/D converter.

Microprocessor: A microprocessor belonging to the x86 family is used for controlling the data acquisition and running the communication protocols. The microprocessor is equipped with 32 MB of memory to store 1 minute of data in case of offline monitoring used for transmitting the recorded data to the concentrator PC. A transfer protocol for data transfer is established and the receiving software is set up appropriately. The transmission of transmitting data to distances over 200m is bandwidth of the transmitter for real time monitoring is chosen to be larger than 1.4Mbps (5760Hz x 15 channels x 16 bits).

2.3 Concentrator

The concentrator device consists of a high capacity wireless receiver connected to a PC which stores and processes data. The concentrator can be set in one of the two modes using the software.

Continuous monitoring: In this mode the concentrator continuously receives recorded data from each IED simultaneously. The transmission bandwidth required for this application is quite high, $n \times 1.4 \text{ Mbps}$, where n is the number of circuit breaker monitors in the system.

Event monitoring: In this mode the concentrator continuously polls the IEDs for their status and if any trip or

close event has occurred the recorded data is uploaded. The transmission bandwidth for this application can be quite low as the data is transmitted offline.

Description CBMA software: CBMA software consists of client and server part. Each of these contains several different modules, performing specific functions mentioned in previous sections of the paper. In this section, we will focus on functional requirements and implementation of the application for analysis of CBM recordings, whose architecture is displayed in Fig.3.




Fig.3. Architecture of analysis application of CBMA

2.4 Signal processing

Signal processing module analyzes the data from CBM recordings using empirically obtained values of signal processing settings and extracts the signal features characterizing the transitions of the analyzed signal waveforms and describing them quantitatively. For example, some of the features extracted are time instances at which the coil current picks up or when the phase current breaks, a measure of voltage drop for the supply DC voltage, magnitude of the noise on the contact signal etc. Waveforms of CB signals are displayed in Fig.5..

SIGNAL TYPE	WAVEFORMS	
	Circuit Breaker OPEN operation	Circuit Breaker CLOSE operation
Trip and Close Initiates	[Waveform showing a step up]	[Waveform showing a step down]
"a" and "b" Contacts	[Waveform showing a step down]	[Waveform showing a step up]
Trip and Close Coil Currents	[Waveform showing a pulse]	[Waveform showing a pulse]
X and Y Coils	None	[Waveform showing pulses for X and Y]
Phase Currents	[Waveform showing AC cycles]	[Waveform showing AC cycles]
DC Voltages	[Waveform showing a step down]	[Waveform showing a step up]

Fig.5. Waveforms of signals from CB control circuit for open and close operations respectively

The signal processing consists of several steps, performed using advanced signal processing techniques. Fourier analysis is used for obtaining the information on frequency spectrum of the signal.

For elimination of measurement noise, removal and extraction of unnecessary signal components of the frequency

spectrum, digital filtering is being used. Wavelet composition and reconstruction algorithm is used for de-noising and separation of signal features.

3. EXPERT SYSTEM

Rule based expert system is implemented in CLIPS 0. Purpose of the expert system in analysis application is to emulate reasoning of a human expert maintaining the circuit breakers. It compares the extracted signal features against the empirically obtained values. Each type of circuit breaker has particularly customized set of rules used for the analysis of the expert system. A rule represents a fragment of knowledge that is used in the decision-making process. Processing of the signal features by the expert system consists of several operations:

Event classification circuit breaker operation is classified such as closing or opening. Based on that conclusion, appropriate set of rules customized for each CB operation is used Signal characterization and verification– each signal describing the event is analyzed based on the rules of the expert system knowledge base. The purpose of this is to verify that the values of extracted signal features conform to the expected values within given tolerances.

Verification of cause effect relationship among signals– the relationships involving multiple parameters and possibly multiple signals are analyzed to determine the causes of observed signal features. Operation verification– overall correctness of the breaker operation needs to be verified by comparing the actual breaker operation against the patterns stored in the rules of the expert system and the settings, each of them customized for particular type of circuit breaker and operation and specified by user.

Analysis report generation– at the end of the analysis, expert system creates the report in the form of a text file. The report clearly describes the operation and performances of the circuit breaker, as well as maintenance and repair recommendations if problems are detected.




Fig.4. Layers of expert system analysis

One of the advantages of rule-based expert systems is that they may be formed in hierarchal structure where some rules are simply intermediate steps to a final conclusion. When the expert system first begins to execute, all of the extracted features and settings (facts) are loaded into the short-term memory. Once the facts are loaded, the inference engine uses the rules stored in long-term memory to analyze the

information given in the facts. The rules were designed to enable the inference engine to perform two layers of analysis on the given data.

Fig.4 shows a graphical representation of the two layers of analysis. The first layer uses a set of basic rules to make sure that all the extracted parameters are within their corresponding tolerances. If a parameter is outside a tolerance, then the rule that checks the parameter becomes activated. The activated rules from the first layer of analysis provide some preliminary results about the circuit breaker condition. The second layer uses a set of complex rules to analyze the interrelationship between all of the activated rules from the first stage. Based on which rules were activated, the expert system tries to come to a conclusion about the overall performance of the breaker. A certain combination of basic rules may indicate a particular problem whereas a different combination would indicate another problem.

The expert system was designed to only analyze a single event or operation at a time. In the case of multiple operations, the data is divided up into a group of single operations and fed into the expert system separately. The results from each layer of the analysis are logged to an analysis report. The report provides useful information about the circuit breaker operation to enable maintenance personnel to fix the problems that are discovered.

4. EXAMPLE OF ANALYSIS

A typical example is given to demonstrate the analysis results obtained by the CBMA solution.

```
(defrule R61
(declare (saliency -1280))
(initial-fact)
(closing)
(not (R61_fired))
(or (R69_fired) (R72_fired) (R75_fired))
(R24_2_fired)
=>
(assert (R61_fired))
(printout t crlf " R61: Stuck breaker while
closing!" crlf)
(printout outFile " R61: Stuck breaker
while closing!" crlf)
)
```

The example chosen for this discussion is a breaker that becomes stuck while opening. This is a common problem found in breakers out in the field and is certainly a problem that requires immediate maintenance. The problem can be diagnosed by analyzing four signals that include the three phase currents that are monitored using the current transformers and the trip coil current that is monitored from the control circuit. The signal abnormalities that characterize this type of problem are displayed in Fig.5.

The trip coil current remains at its maximum steady state value and one or more phase currents do not drop to zero.

Only one phase current is shown because one abnormal phase is sufficient to detect and classify the problem. The other phase currents may be normal or abnormal.




Fig.5.Signal abnormalities for a stuck breaker

In extracts two time parameters that corresponds to the time instants where the trip coil goes to zero and the time instant where the phase current goes to zero. If a signal does not make a transition to zero, then a minus one replaces the corresponding time parameter. These parameters are sent to the expert system for analysis. The expert system uses two basic rules to determine if the trip coil and phase currents go to zero. When both basic rules become activated, a complex rule called stuck breaker also becomes activated to indicate the breaker had a problem during the opening operation. The complex rule for a stuck breaker is given in **Error! Reference source not found.** Rules 69, 72, and 75 checks that each of the phase currents made a transition to zero. Rule 24 analyzes the trip current fact to see if it made transition to zero.

5. CONCLUSION

The new CBMA system for real-time monitoring and assessment of circuit breaker operations provides for better understanding of condition and operating performance of each individual breaker by monitoring and analyzing expanded set of analog and digital signals from circuit breaker control circuitry. Permanently monitoring and automatically analyzing the circuit breaker data recorded for each operation enable real time monitoring of integrity and topology of the entire power network. This solution facilitates the analysis process by providing timely results that are consistent, irrespective of who runs the analysis.

Enhanced reasoning, consistency and speed are achieved by using advanced signal processing and expert system techniques. The archiving and retrieving functions supported by database and web server, enable an easy access to the historical data, reports and dissemination across the company.

System features high speed, network wide, programmable trouble notifications. Using low cost, off-shell components for implementation of Circuit Breaker Monitor (CBM), cost of the system is significantly lowered. Wireless link for communication and transfer of data from CBM to the concentrator PC increases the flexibility of the system, which provides important advantage over hardwired solutions.

REFERENCES

- [1] M. Kezunovic, Z. Ren, G. Latisko, D. R. Sevcik, S. Lucey, W.E. Cook, E.A. Koch, "Automated Monitoring and Analysis of Circuit Breaker Operation", *IEEE Transactions on Power Delivery*, [accepted for press].
- [2] IEEE Std. C37.111-1991 "IEEE Standard Common Format for Transient Data Exchange (COMTRADE) for Power Systems", *IEEE Inc.*, 1991.
- [3] IEEE Inc., 1999 "IEEE Standard Common Format for Transient Data Exchange (COMTRADE) for Power Systems", *IEEE Std. C37.111-1999*.
- [4] Final Report of IEEE Power System Relaying Committee Working Group H8, 2001, "File Naming Convention for Time Sequence Data", *Fault Disturbance Analysis Conference, Atlanta, Georgia; and the Spring 2001 Meeting of the IEEE Power System Relay Committee*.
- [5] P.Dhivya and A.Sivakumar, Enhancement of Quality in a Transmission Grid using UPQC with Fuzzy and Neuron Fuzzy Logic Controller, *Asian Journal of Applied Science and Technology*, Volume 1, Issue 1, Pages 1-3.
- [6] G. Ramya and N.Balakumar, Effectual and Lossless Electrical Power Generation Methodology using Wind-Lens Technology, *Asian Journal of Applied Science and Technology*, Volume 1, Issue 1, Pages 12-17.
- [7] J.Jasmine Christina and V.Karthikeyan, Design of low power oscillator for medical ultrasonic sensors with CMUT implementation, *Asian Journal of Applied Science and Technology*, Volume 1, Issue 1, Pages 68-72.
- [8] S.Sowmiya, K.Stella and V.M.Senthilkumar, Design and analysis of 4-2 compressor for arithmetic application, *Asian Journal of Applied Science and Technology*, Volume 1, Issue 1, Pages 106-109.
- [9] D.Ramesh Kumar and P.Mohanraj, Design and analysis of rotavator blades for its enhanced performance in tractors, *Asian Journal of Applied Science and Technology*, Volume 1, Issue 1, Pages 160-185.